
DEFENSE DISTRIBUTION CENTER SUSQUEHANNA PENNSYLVANIA

NEW CUMBERLAND, PENNSYLVANIA

REPLACEMENT TO HVAC SYSTEM IN BUILDING 286



DRAWING INDEX

DRAWING # — DRAWING NAME SHEET #

GENERAL

M-1 - BUILDING 286 PLANS AND SCHEDULES M-2 - HVAC DETAILS AND DIAGRAMS

HVAC COMPONENTS

DUCT, FIRST VALUE IS SIDE SHOWN

LOW VOLTAGE OR CONTROL WIRING

CEILING MOUNTED GRILLE OR REGISTER

DIFFUSER, 4-WAY BLOW

REVISION REFERENCE

SHEET KEYNOTES

AREA AFFECTED BY REVISION.

ELEMENTS TO BE

ABBREVIATIONS

ACCU	AIR COOLED CONDENSING UNIT	GAL	GALLONS
ACU	AIR CONDITIONING UNIT	G	GAS
AD	ACCESS DOOR OR AIR DRYER	GPM	GALLONS PER MINUTE
AHU	AIR HANDLING UNIT	HVAC	HEATING, VENTILATING & AIR CONDITIONING
APPROX	APPROXIMATE	HZ	FREQUENCY
AVG	AVERAGE	INFO	INFORMATION
BDD	BACKDRAFT DAMPER	IN WC	INCHES IN WATER COLUMN
BTU	BRITISH THERMAL UNITS	KW	KILOWATTS
BTUH	BRITISH THERMAL UNITS PER HOUR	LAT	LEAVING AIR TEMPERATURE
CD	CEILING DIFFUSER	LBS	POUNDS
CFM	CUBIC FEET PER MINUTE	LDB	LEAVING DRY BULB TEMPERATURE
CONN	CONNECTION	LWB	LEAVING WET BULB TEMPERATURE
CR	CEILING RETURN	LWT	LEAVING WATER TEMPERATURE
CUH	CABINET UNIT HEATER	MBH	1000 BTUH
DB	DRY BULB	NC	NORMALLY CLOSED OR NOISE CRITERIA
DN	DOWN	NTS	NOT TO SCALE
DWG	DRAWING	OA	OUTSIDE AIR
DX	DIRECT EXPANSION	PD	PRESSURE DROP
EA	EXHAUST AIR	PSI	POUNDS PER SQUARE INCH
EAT	ENTERING AIR TEMPERATURE	RA	RETURN AIR
EDB	ENTERING DRY BULB TEMPERATURE	RG	RETURN GRILLE
EF	EXHAUST FAN	RR	RETURN REGISTER
EG	EXHAUST GRILLE	SA	SUPPLY AIR
EL	ELEVATION	SF	SUPPLY FAN
ER	EXHAUST REGISTER	SHT	SHEET
ESP	EXTERNAL STATIC PRESSURE	SP	STATIC PRESSURE
EUH	ELECTRIC UNIT HEATER	SPEC	SPECIFICATION
EWB	ENTERING WET BULB TEMPERATURE	SS	STAINLESS STEEL
EWC	ELECTRIC WATER COOLER	STD	STANDARD
EWT	ENTERING WATER TEMPERATURE	TEMP	TEMPERATURE
EXIST	EXISTING	TG	TRANSFER GRILLE
FD	FIRE DAMPER OR FLOOR DRAIN	TYP	TYPICAL
FMS	FACILITY MANAGEMENT SYSTEM (HVAC)	UH	UNIT HEATER
FPM	FEET PER MINUTE	UL	UNDERWRITERS LABORATORIES
FPS	FEET PER SECOND	WB	WET BULB

INTERPRETATION OF DRAWINGS

FT FEET

THE MECHANICAL DRAWINGS CANNOT BE FULLY AND CORRECTLY INTERPRETED WITHOUT REFERENCE TO SPECIFICATIONS SYMBOLS, SCHEDULES, AND ABBREVIATIONS.

WPD WATER PRESSURE DROP

ANY OF THE SYMBOLS AND ABBREVIATIONS MAY APPEAR ON THE DRAWINGS, USE ONLY THOSE PERTAINING TO THESE DOCUMENTS.

THE MECHANICAL DRAWINGS ARE DIAGRAMMATIC AND ARE INTENDED TO INDICATE CAPACITY, SIZE, APPROXIMATE LOCATION AND GENERAL ARRANGEMENT, NOT THE SPECIFIC DETAILS OF CONSTRUCTION AND INTERCONNECTION OF SYSTEMS.

NO.			REVISIONS		DATE
CONSTRUCTION I		OVED BY OFFICE OF COMMAND SECURITY	DEFEN DEFENSE DISTRIBUT FACILITIES ENGIN	SE LOGISTICS AGENOTION DEPOT SUSQUEHANNA, PRIEERING DIVISION, ENGINEERING UMBERLAND, PA 17070-5002	CY ENNSYLVANIA G BRANCH
ENVIRONMEN	TAL BRANCH	SAFETY AND HEALTH		REPLACEMENT TO HVAC YSTEM IN BUILDING 286	
FIRE PROTECT	TION BRANCH	OFC. OF TEL. AND COMM. INFO. SYSTEMS		COVER SHEET	
INDUSTRIAL	HYGIENIST	USER	DESIGNED BY: PWH/GWS	CHECKED BY:	PROJECT NO. 3628 DRAWING NO.
MAINTENANCE OP	ERATION BRANCH		drawn by: EMC	ELEC. ENGR	CS-1 SHEET 1 OF 3
ROB MON	NTEFOUR	FACILITIES ENGINEER	scale: AS NOTED	ARCHITECT SUPR. ENGR	DATE JULY 08

						PA	CKA	GED	RO	OFT	OP A	AIR H	AND	LIN	G UN	IT SC	HED	ULI						
		SI	JPPLY FAN					MIN		ELEC	CTRICAL	DATA		GAS	HEAT			COOLI	NG			APPROX		BASIS OF DEDIGN
TAG	TOTAL	SERVING	MAX OA	MIN OA	ESP (IN	MAX	FAN HP	SEER	VOLTS	PHASE	HERTZ	MIN CKT	MAX	MBH	EAT	TOTAL	SENS.	EDB	EWB	LDB	LWB	OPERATING	REMARKS	MANUFACTURER
	CFM	SERVING	CFM	CFM	WC)	RPM	FANTE	(ARI)	VOLIS	FIASE	HERIZ	AMP	CKT	IVIDIT	LAI	MBH	MBH	°F	°F	°F	°F	WT. (LBS)		MODEL
PRTU-101	1,000	MAIN ROOM	1,000	300	0.50	1500	1	13	208	3	60	27	40	72.9	52.5	41.9	26.5	79.2	67	55.0	53.3	950	PROVIDE WITH ADAPTOR CURB	AAON RM-A04-8
PRTU-102	800	ADJACENT SMALLER ROOMS	800	250	0.5	1400	1	13	208	3	60	19	25	55.9	51.6	34.1	21.4	79.4	67.2	55	53.3	900	PROVIDE WITH ADAPTOR CURB	AAON RM-A03-8

NOTE: PACKAGED ROOFTOP UNIT COOLING CAPACITY BASED ON 95F ABMIENT AIR TEMPERATURE

							FAN	I SCH	HEDL	JLE		
TAG	SERVING	TYPE	AIRFLOW	ESP (IN W.G.)	DRIVE	MAX RPM	MOTOR	ELE	CTRICAL D	DATA	METHOD OF CONTROL	REMARKS
17.0	OLIVINO	1111 -	(CFM)	LOI (IIV VV.O.)	DIXIVE		H.P.	VOLTS	PHASE	HERTZ	WEITIOD OF GOINTIGE	TEIWAITIO
F-101	LADIES ROOM	CEILING	150	0.375	DIRECT	1200	1/6	120	1	60	12 HR TIMER WALL SWITCH	
F-102	MENS	CEILING	215	0.375	DIRECT	1400	1/4	120	1	60	13 HR TIMER WALL SWITCH	

1. PROVIDE WITH SOLID STATE SPEED CONTROLLER MOUNTED ON SIDE OF FAN FOR VOLUME CONTROL

			REGISTER, (GRILLE	, AND D	IFUSER SCHEDULE		
TAG	MAXIMUM CFM	DUCT SIZE (IN)	DESCRIPTION	S.P. (IN WG)	VERTICAL THROW (FT.) AT 100 FPM	REMARKS AND DIRECTION OF FLOW	MAX NC LEVEL	MANUFACTURER MODEL BASIS OF DESIGN
CD-A	225	8	CEILING DIFFUSER	0.07	-	24 X24 PANEL	20	TITUS TCD
CD-B	225	8	CEILING DIFFUSER	0.07	-	24 X24 PANEL - 3 WAY BLOW	20	TITUS TCD
EG-A	1500	22 x 22	EGG CRATE GRILLE	0.025		24 X 24 EGG CRATE GRILLE	15	TITUS 50FF

			ELEC	CTRIC	WALL	HEA	TER S	CHED	ULE	
TA	G TYPE	KW	BTUH	VOLTS	CTRICAL DA	ATA HERTZ	FAN MOTOR HP	HEATING STAGES	AIRFLOW (CFM)	REMARKS
EWI	I-A SEMI-RECESSED	1.5	5.1	208	1	60	-	1	-	INTEGRAL THERMOSTAT

- 1. DEMOLISH EXISTING DIFFUSER/GRILLE/REGISTER.
- 2. DEMOLISH EXISTING PACKAGED ROOFTOP AIR CONDITIONING UNIT (PRTU). PREPARE EXISTING DUCTWORK FOR CONNECTION TO NEW PRTU.
- 3. DEMOLISH EXISTING EXHAUST FANS. PREPARE EXISTING DUCTWORK OF CONNECTION TO NEW FAN.
- 4. CONNECT NEW DIFFUSER TO EXISTING DUCTWORK. EXISTING FLEXIBLE RUNNOUT MAY BE REUSED IF THERE ARE NO RIPS OR TEARS IN THE DUCTWORK OR INSULATION/VAPOR BARRIER, OTHERWISE REPLACE FLEXIBLE DUCTWORK IN KIND.
- 5. CONNECT EXISTING SUPPLY AND RETURN DUCTWORK TO NEW PRTU. PROVIDE ADAPTOR CURB CONNECTION AS NECESSARY.
- 6. CONNECT NEW NATURAL GAS PIPING TO EXISTING UNDERGROUND PIPING.
- 7. ADD PRESSURE REGULATOR AND STOP VALVES AS PER THE NATURAL GAS UTILITY REQUIREMENTS. REDUCE PRESSURE FROM 10 PSIG TO 16" WG
- 8. EXTEND NATURAL GAS PIPING FROM GRADE THROUGH SOFFIT INTO CEILING PLENUM.
- 9. NATURAL GAS PIPING UP TO ROOF. ROOF PENETRATION SHALL BE THROUGH A MANUFACTURED PIPING CURB ASSEMBLY.
- 10. NATURAL GAS PIPING CONNECTION TO PRTU WITH PRESSURE REGULATOR AND STOP VALVE.

- 11. DEMOLISH FLEXIBLE DUCTWORK AND RETURN AIR GRILLE. MAKE FLEXIBLE DUCTWORK CONNECTION TO RIGID DUCTWORK READY FOR INSTALLATION OF NEW FLEXIBLE RETURN AIR DUCTWORK (ENLARGE OR CAP AND PATCH).
- 12. NEW RETURN AIR FLEXIBLE DUCTWORK AND GRILLE. CONNECT TO EXISTING RETURN AIR RIGID DUCTWORK.
- 13. DISCONNECT EXISTING UNITS AND RECONNECT TO EXISTING CONDUCTORS. CONTRACTOR SHALL PROVIDE EXTERNAL RATED DISCONNECT SWITCH (40A FOR PRTU-101, AND 30A FOR PRTU-102).
- 14. REPLACE TWO (2) EXISTING 50A/3P CIRCUIT BREAKERS IN EXISTING PANEL BOARD WITH APPROPRIATE SIZED BREAKERS FOR NEW ROOFTOP UNITS. (FURNISH 3# 8+1# 10 GRD -¾" CONDUIT FOR PRTU-101; AND FURNISH 3# 10+1# 10 GRD -¾" CONDUIT FOR PRTU-102)
- 15. 1" GAS PIPING ON ROOF.
- 16. POLYCARBONATE NATURAL GAS PIPE SUPPORT MIRO MODEL 3—RAH—7 OR EQUIVALENT.
- 17. IN RESTROOMS DEMOLISH EXISTING LAYIN CEILING TILES AND BATT INSULATION ON CEILING TILES. CEILING GRID TO REMAIN.
- 18. IN RESTROOMS REPLACE CEILING TILES WITH CERAMIC MINERAL COMPOSITE LAYIN CEILING TILE WITH FACTORY APPLIED PLASTIC FINNISH, ARMSTRONG CERAMAGUARD OR EQUIVALANT. REPLACE BATT INSULATION WITH 9" FOIL FORCED FIRBERGLASS BATT INSULATION LAID ON THE CEILING TILES WITH THE VAPOR BARRIER FACING DOWN.

(14)	VERIFY LOCATION)	CD-A-155	CD-A-155
<u> </u>	-A-100 CD-A-10		
8 4	18X8 PRTU	14X8	SX8 & & 4
XX \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	18X8 ———————————————————————————————————	10X8 5 EG-A 4	EG-A
©EWH-A S N	1"	0	
EG-A	CD-A-165	CD-B-165	CD-A-165
225 CFM \$\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	8 8	Q Q Q Q Q Q Q Q Q Q	8
<u>F-103</u>	14X8	1	4X8
150 CFM	PRTU		-(15)
80	₩ 12 0 Gt	16¢ EG-A & & G-1	m m m m m m m m m m m m m m m m m m m
EG-A	4	16	1" (4)
\$ 4 0	CD-A-165	CD-B-165	CD-A-165
CD-A-150		9	p
		FOR CONTINUATION SEE SITE PLAN THIS SHEET,	

EXISTING PANEL

BUILDING 286 DEMOLITION PLAN

SCALE: 1/8" = 1'-0"


BUILDING 286 SITE NEW WORK PLAN

SCALE: 1/16" = 1'-0"

PLAN THIS SHEET

BUILDING 286 NEW WORK PLAN

SCALE: 1/8" = 1'-0"



NO.			REVISIONS		DAT					
APPROVED BY CONSTRUCTION REPRESENTATIVE OFFICE OF COMMAND SECURITY			DEFENSE LOGISTICS AGENCY DEFENSE DISTRIBUTION DEPOT SUSQUEHANNA, PENNSYLVAN FACILITIES ENGINEERING DIVISION, ENGINEERING BRANCH NEW CUMBERLAND, PA 17070-5002							
ENVIRONMENTAL BRANCH SAFETY AND HEALTH		REPLACEMENT TO HVAC SYSTEM IN BUILDING 286								
FIRE PROTECT	TION BRANCH	OFC. OF TEL. AND COMM. INFO. SYSTEMS	BUILDII	NG 286 PLANS AND SCHED	JLES					
INDUSTRIAL	HYGIENIST	USER	DESIGNED BY: PWH/GWS DRAWN BY: EMC	CHECKED BY: CIVIL ENGR	PROJECT NO 3628 DRAWING NO M-1 SHEET					
MAINTENANCE OPE		FACILITIES ENGINEER	scale: AS NOTED	MECH. ENGR ARCHITECT SUPR. ENGR	2 of					

